

Water Audit Validation Certificate

Part A: Provided by Validator

Audit Information:

Water Supplier Name: Corona DWP

PWS ID: 3310037

System Type: Potable

Audit Period: Fiscal Year 2018/19

Utility Representation: Stacy Joyce, Reg Tech III; Melissa Estrada-Maravilla, Ops Analyst; Justin Amon, Chief Wtr Operator; Chase Michelotti, Chief Distr Operator

Validation Date: 09/23/2019

Call Time: 8:00am

Sufficient Supporting Documents Provided: Yes

Validation Findings& Confirmation Statements:

Key Audit Metrics:

Data Validity Score: 63

Data Validity Band (Level): Level III (51-70)

ILI: 0.62

Real Loss: 723.036 acre-ft./yr.

Apparent Loss: 695.587 acre-ft./yr.

Non-revenue water as percent of cost of operating system: 3.4%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit.



If not, rejected recommendations are included here.

Validator Information:

Water Audit Validator: Damian Martinez

Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

Validator Provided

Damian Martinez WAV

Water Audit Validation Certificate

Part B: Provided by Utility**Water Supplier Name:** City of Corona DWP**Water Supplier ID Number:** 3310037**Water Audit Period:** Fiscal Year 2018/19**Water Audit & Water Loss Improvement Steps:**

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

- 1) Thoroughly reviewed water supplied calculations to ensure all sources were accounted for.
- 2) Continued to efficiently track and code operational costs which resulted in confident operating water system calculations.

Utility Provided

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, Water Audit and Loss Control Programs, Manual 36, Fourth Edition and in the Free Water Audit Software Version 5.

DS
kH

Executive Name (Print)

Tom Moody

Executive Position

General Manager

Signature

DocuSigned by:

Tom Moody

D519EFD915CF45C...

Date

9/26/2019

Damian Martinez WAV